



MCL



महाप्रबंधक/ (सामग्री प्रबंधक) विभाग प्रमुख का कार्यालय

Office of General Manager (MM)/HOD

महानदी कोल्फील्ड्स लिमिटेड

(भारत सरकार का उद्यम)

MAHANADI COALFIELDS LIMITED

(A Government of India Enterprise)

Jagriti vihar Burla Sambalpur Pin no.768020 (Odisha)

Ref No.: MCL/HQ/GM(MM)/2023-24/Corrgnd/GEMC-511687707376791-01 Dtd 10.11.2023

To,
M/s NETCO CABLE INDUSTRIES PRIVATE LIMITED
B-11/1,,NETCO, OKHLA INDUSTRIAL AREA,
PHASE-2, New Delhi,
DELHI-110020

Subject: Corrigendum to the Supply order no. GEMC-511687707376791 dtd 10.11.2023

Ref: GeM contract no: GEMC-511687707376791 dtd 10.11.2023

Dear Sir,

The unit rate and extended order value may please be read as follows in place of the existing entries in the contract GEMC-511687707376791 dtd 10.11.2023

| Sl no. | Material description and size | Qty (mtr) | Unit Price inclusive of taxes (Rs) | Extended order value (Inclusive of taxes) Rs |
|--|---|-----------|------------------------------------|--|
| 1. | Product Name: Netco Make 3.3KV PVC DWA Copper Power Cable 35sqmm Brand NETCO, Brand Type Registered Brand, Category Name and Catalogue Quadrant: PVC Insulated (Heavy Duty) Electric Cables, Suitable for use in Mines as per IS 1554 (Part 2) (Q3) Model Netco 3.3kv_Cu 35sqmm | 2500 | 1172.92 | 29,32,300.00 |
| 2. | Product Name : Netco Make 3.3KV PVC DWA Copper Power Cable 70sqmm Brand NETCO Brand Type Registered Brand Category Name & Quadrant PVC Insulated (Heavy Duty) Electric Cables, Suitable for use in Mines as per IS 1554 (Part 2) (Q3), Model Netco 3.3kv_Cu 70sqmm | 3300 | 2200.70 | 72,62,310.00 |
| 3. | Product Name: Netco Make 3.3KV PVC DWA Copper Power Cable 95sqmm Brand: NETCO Brand Type: Registered Brand Category Name & Quadrant: PVC Insulated (Heavy Duty) Electric Cables, Suitable for use in Mines as per IS 1554 (Part 2) (Q3) Model Netco 3.3kv_Cu 95sqmm | 2900 | 2999.56 | 86,98,724.00 |
| Total inclusive of taxes (Rs) | | | | 1,88,93,334.00 |
| Rs. One Crore Eighty Eight Lakhs Ninety Three Thousand Three Hundred Thirty Four Only | | | | |

२२/३

All other terms and conditions of the supply order remains unaltered

Thanking you

Regards

(S/O)
10/11/23

Dy Manager(MM)/Pur
MCL, HQ

Copy To:

1. The General Manager (E&M)/HoD, MCL HQ
2. Paying Authority: Manager(F), MCL HQ (Kind Attn: Deepak Kumar Burma)
3. Consignee: Depot Officer, Central store Jagnath Area/ Lakhanpur Area
4. Office Copy.

Contract | अनुबंध



Contract No | अनुबंध क्रमांक: GEMC-511687707376791

Generated Date | अनुबंध तिथि: 10-Nov-2023

Bid/RA/PBP No. | बोली/आरए/पीबीपी संख्या: [GEM/2023/B/3346784](#)

Schedule Name | अनुसूची नाम: Schedule 1, Schedule 3, Schedule 4

| Organisation Details संगठन विवरण | Buyer Details खरीदार विवरण |
|--|---|
| Type प्ररूप: Central PSU Ministry मंत्रालय: Ministry of Coal Department विभाग: MAHANADI COALFIELDS LIMITED Organisation Name संगठन का नाम: MAHANADI COALFIELDS LIMITED Office Zone कार्यालय क्षेत्र: MAHANADI COALFIELDS LIMITED | Designation पद: Sunil Dajgude Dy Mgr MM Contact No. संपर्क नंबर: - Email ID ईमेल आईडी: sunilt.dajgude@coalindia.in GSTIN जीएसटीआईएन: 21AABCM5188P1Z3 Address पता: MAHANADI COALFIELDS LIMITED, PO - JAGRUTI VIHAR, BURLA, SAMBALPUR, ODISHA-768020, India |

| Financial Approval Detail वित्तीय स्वीकृति विवरण | Paying Authority Details भुगतान प्राधिकरण विवरण |
|---|--|
| IFD Concurrence आईएफडी सहमति: No Designation of Administrative Approval प्रशासनिक अनुमोदन का पदनाम: GM(MM)/HOD Designation of Financial Approval वित्तीय अनुमोदन का पदनाम: DY GM(FIN) | Role: PAO Payment Mode भुगतान का तरीका: Internet Banking Designation पद: DEEPAK KUMAR BURMA MGR FIN Email ID ईमेल आईडी: dkburma@coalindia.in GSTIN जीएसटीआईएन: 21AABCM5188P1Z3 Address पता: MAHANADI COALFIELDS LIMITED, AT /PO - JAGRUTI VIHAR, BURLA, SAMBALPUR, ODISHA-768020, India |

| Seller Details विक्रेता विवरण | |
|--|--|
| GeM Seller ID जेम विक्रेता आईडी: 9969200001307203 Company Name कंपनी का नाम: NETCO CABLE INDUSTRIES PRIVATE LIMITED Contact No. संपर्क नंबर: 09312231694 Email ID ईमेल आईडी: netcocable1@gmail.com Address पता: B-11/1,,NETCO, OKHLA INDUSTRIAL AREA, PHASE-2,OKHLA INDUSTRIAL AREA, PHASE-2, New Delhi, DELHI-110020, - MSME Registration number एमएसएमडी पंजीकरण संख्या: - GSTIN जीएसटीआईएन: 07AAACN2751J1ZI | |

*GST / Tax invoice to be raised in the name of | जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा - Consignee

Delivery Instructions | वितरण निर्देश: NA

| # | Item Description आइटम विवरण | Ordered Quantity आइटम विवरण | Unit इकाई | Unit Price (INR) इकाई मूल्य (INR) | Tax Bifurcation (INR) कर विभाजन (INR) | Price (Inclusive of all Duties and Taxes in INR) मूल्य (INR में सभी शुल्क और कर सहित) |
|---|--|-------------------------------|-------------|-------------------------------------|---|---|
| 1 | Product Name उत्पाद का नाम: Netco Make 3.3KV PVC DWA Copper Power Cable 35sqmm Brand ब्रांड: NETCO Brand Type ब्रांड प्रकार: Registered Brand Catalogue Status कैटलॉग की स्थिति: Catalogue not verified by OEM Selling As कैसे बेचा जा रहा है: OEM verified Reseller Category Name & Quadrant श्रेणी का नाम और चतुर्थांश: PVC Insulated (Heavy Duty) Electric Cables, Suitable for use in Mines as per IS 1554 (Part 2) (Q3) Model मॉडल: Netco_3.3kv_Cu_35sqmm HSN Code एचएसएन कोड: HSN not specified by seller | 2,500 | meter | 1,186.8 | NA | 2,967,000 |
| 2 | Product Name उत्पाद का नाम: Netco Make 3.3KV PVC DWA Copper Power Cable 70sqmm Brand ब्रांड: NETCO Brand Type ब्रांड प्रकार: Registered Brand Catalogue Status कैटलॉग की स्थिति: Catalogue not verified by OEM Selling As कैसे बेचा जा रहा है: OEM verified Reseller Category Name & Quadrant श्रेणी का नाम और चतुर्थांश: PVC Insulated (Heavy Duty) Electric Cables, Suitable for use in Mines as per IS 1554 (Part 2) (Q3) Model मॉडल: Netco_3.3kv_Cu_70sqmm HSN Code एचएसएन कोड: HSN not specified by seller | 3,300 | meter | 2,223 | NA | 7,335,900 |
| | Product Name उत्पाद का नाम: Netco Make 3.3KV PVC DWA Copper Power Cable 95sqmm Brand ब्रांड: NETCO Brand Type ब्रांड प्रकार: Registered Brand Catalogue Status कैटलॉग की स्थिति: Catalogue not verified by OEM | | | | | |

| | | | | | | |
|---|--|-------|-------|---------|----|-----------|
| 3 | Selling As कैसे बेचा जा रहा है : OEM verified Reseller Category Name & Quadrant श्रेणी का नाम और चतुर्थांश : PVC Insulated (Heavy Duty) Electric Cables, Suitable for use in Mines as per IS 1554 (Part 2) (Q3) Model मॉडल: Netco_3.3kv_Cu_95sqmm HSN Code एचएसएन कोड: HSN not specified by seller | 2,900 | meter | 3,061.6 | NA | 8,878,640 |
|---|--|-------|-------|---------|----|-----------|

Total Order Value | कुल ऑर्डर मूल्य (in INR) **19,181,540**

Consignee Detail | परेषिती विवरण

| S.No क्र.सं. | Consignee परेषिती | Item वस्तु | Lot No. लॉट नंबर | Quantity मात्रा | Delivery Start After दैनिक के बाद डिलीवरी शुरू करना है | Delivery To Be Completed By वितरण पूरा कब तक करना है |
|----------------|---|--|--------------------|-------------------|--|--|
| 1 | Designation पद : - Email ID ईमेल आईडी : depot-off-jaga.mcl@nic.in Contact संपर्क : 94388-77340- GSTIN जीएसटीआईएन : 21AABCM5188P1Z3 Address पता : Office of the Depot Officer, Central/Regional Stores, Jagannath /Area, P.O. Balanda, ANGUL, ODISHA-759116, India | Netco Make 3.3KV PVC DWA Copper Power Cable 35sqmm | - | 1,300 | 10-Nov-2023 | 09-Mar-2024 |
| | | Netco Make 3.3KV PVC DWA Copper Power Cable 70sqmm | - | 1,900 | 10-Nov-2023 | 09-Mar-2024 |
| | | Netco Make 3.3KV PVC DWA Copper Power Cable 95sqmm | - | 1,450 | 10-Nov-2023 | 09-Mar-2024 |
| 2 | Designation पद : - Email ID ईमेल आईडी : depot-off-ikpa.mcl@coalindia.in Contact संपर्क : 094-38877590- GSTIN जीएसटीआईएन : 21AABCM5188P1Z3 Address पता : Office of the Chief General Manager, Mahanadi Coalfields Limited, Lakhanpur Area, At/PO Bandhbahal, Via, Belpahar, JHARSUGUDA, ODISHA-768211, India | Netco Make 3.3KV PVC DWA Copper Power Cable 35sqmm | - | 1,200 | 10-Nov-2023 | 09-Mar-2024 |
| | | Netco Make 3.3KV PVC DWA Copper Power Cable 70sqmm | - | 1,400 | 10-Nov-2023 | 09-Mar-2024 |
| | | Netco Make 3.3KV PVC DWA Copper Power Cable 95sqmm | - | 1,450 | 10-Nov-2023 | 09-Mar-2024 |

Product Specification for Netco Make 3.3KV PVC DWA Copper Power Cable 35sqmm

| Specification विनिर्देश | Sub-Spec उप-विनिर्देश | Value मूल्य |
|--|---|------------------------------------|
| GENERIC | PVC Insulated (Heavy Duty) Electric cables for working voltages from 3.3 kV up to and including 11 kV conforming to | IS:1554-Part 2: 1988 latest |
| | ISI Marked | Yes |
| | BIS Marked if "Yes" BIS License Number (CM/L Number) - Must declare | CM/L 8051865 |
| | Cable Category | 01 |
| | Types of cable | "Three-core armoured, unscreened" |
| | Voltage Grade | 3.3/3.3 kV |
| | Conductor material (as per Cl.3 of IS:1554 (Part 2):1988 latest) | Copper |
| | Insulation Type (as per Cl.4.1 of IS:1554 (Part 2):1988 latest) | Type A |
| | Outer sheath type | Type ST1 |
| CONSTRUCTIONAL | Nominal Area of Conductor (in Sq.mm)" | 35 |
| | Armouring | Galvanized Double steel round wire |
| | Cable packing type (Wound on drum) (as per Cl. 21 of IS:1554 (Part 2): 1988 latest) | Yes |
| | Identification on cable as per Cl. 20 of IS:1554 (Part 2): 1988 latest | Yes. Marked |
| CERTIFICATIONS | Marking on cable (as per Cl. 21 of IS:1554 (Part 2): 1988 latest) | Yes. Marked |
| | Availability of Type test report with additional requirements for use in Mines from Central Government/NABL/ILAC accredited laboratory to prove conformity to the specification | Yes |
| | Test report number - Must declare | ATCC2015091205 |
| | Report date - Must declare | 12-09-2015 |
| | Name of lab - Must declare | Amit Test |
| | Address of lab - Must declare | 19/168 Saral Rohilla |
| All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand | Yes | |

| Buyer Defined Additional Specification for खरीदार परिभाषित अतिरिक्त विशिष्टता के लिए Netco Make 3.3KV PVC DWA Copper Power Cable 35sqmm | | |
|--|---|------------------------------------|
| Specification विनिर्देश | | Value मूल्य |
| 1. PVC Insulated (Heavy Duty) Electric cables for working voltages from 3.3 kV up to and including 11 kV conforming to : IS:1554-Part 2: 1988 latest 2. ISI Marked : Yes, 3. Conductor material (as per Cl.3 of IS:1554 (Part 2):1988 latest) : Copper | | Agree |
| 4. Outer sheath type : Type ST1 5. Identification on cable as per Cl. 20 of IS:1554 (Part 2): 1988 latest : Yes. Marked 6. Marking on cable (as per Cl. 21 of IS:1554 (Part 2): 1988 latest : Yes. | | Agree |
| 7. Cable packing type (Wound on drum) (as per Cl. 21 of IS:1554 (Part 2): 1988 latest : Yes 8. All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand: Yes | | Agree |
| 9. Availability of Type test report with additional requirements for use in Mines from Central Government/NABL/ILAC accredited laboratory to prove conformity to the specification: Yes 10. Reel length / cable length in a drum: 300 Mtrs +/- 5% | | Agree |
| 11. Self certificate from the manufacturer to the following extent that 3.3 kV grade cables for use in mine are as per DGMS circular no. DGMS/Tech. Circular (Electrical), (Approval) No. 12 Dhanbad, dated 25.05.2015 and IS 1554 Part 2. | | Agree |
| Product Specification for Netco Make 3.3KV PVC DWA Copper Power Cable 70sqmm | | |
| Specification विनिर्देश | Sub-Spec उप-विनिर्देश | Value मूल्य |
| GENERIC | PVC Insulated (Heavy Duty) Electric cables for working voltages from 3.3 kV up to and including 11 kV conforming to | IS:1554-Part 2: 1988 latest |
| | ISI Marked | Yes |
| | BIS Marked if "Yes" BIS License Number (CM/L Number) - Must declare | CM/L 8051865 |
| | Cable Category | 01 |
| | Types of cable | "Three-core armoured, unscreened" |
| | Voltage Grade | 3.3/3.3 kV |
| | Conductor material (as per Cl.3 of IS:1554 (Part 2):1988 latest) | Copper |
| | Insulation Type (as per Cl.4.1 of IS:1554 (Part 2):1988 latest) | Type A |
| | Outer sheath type | Type ST1 |
| | Nominal Area of Conductor (in Sq.mm)" | 70 |
| CONSTRUCTIONAL | Armouring | Galvanized Double steel round wire |
| | Cable packing type (Wound on drum) (as per Cl. 21 of IS:1554 (Part 2): 1988 latest | Yes |
| | Identification on cable as per Cl. 20 of IS:1554 (Part 2): 1988 latest | Yes. Marked |
| | Marking on cable (as per Cl. 21 of IS:1554 (Part 2): 1988 latest | Yes. Marked |
| CERTIFICATIONS | Availability of Type test report with additional requirements for use in Mines from Central Government/NABL/ILAC accredited laboratory to prove conformity to the specification | Yes |
| | Test report number - Must declare | ATCC2015091207 |
| | Report date - Must declare | 12-09-2015 |
| | Name of lab - Must declare | Amit Test |
| | Address of lab - Must declare | 19/168 Saral Rohilla |
| | All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand | Yes |
| Buyer Defined Additional Specification for खरीदार परिभाषित अतिरिक्त विशिष्टता के लिए Netco Make 3.3KV PVC DWA Copper Power Cable 70sqmm | | |
| Specification विनिर्देश | | Value मूल्य |
| 1. PVC Insulated (Heavy Duty) Electric cables for working voltages from 3.3 kV up to and including 11 kV conforming to : IS:1554-Part 2: 1988 latest 2. ISI Marked : Yes, 3. Conductor material (as per Cl.3 of IS:1554 (Part 2):1988 latest) : Copper | | Agree |
| 4. Outer sheath type : Type ST1 5. Identification on cable as per Cl. 20 of IS:1554 (Part 2): 1988 latest : Yes. Marked 6. Marking on cable (as per Cl. 21 of IS:1554 (Part 2): 1988 latest : Yes. | | Agree |
| 7. Cable packing type (Wound on drum) (as per Cl. 21 of IS:1554 (Part 2): 1988 latest : Yes 8. All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand: Yes | | Agree |

| 9. Availability of Type test report with additional requirements for use in Mines from Central Government/NABL/ILAC accredited laboratory to prove conformity to the specification: Yes 10. Reel length / cable length in a drum: 250 Mtrs +/- 5% | | Agree |
|--|---|------------------------------------|
| 11. Self certificate from the manufacturer to the following extent that 3.3 KV grade cables for use in mine are as per DGMS circular no. DGMS/Tech. Circular (Electrical), (Approval) No. 12 Dhanbad, dated 25.05.2015 and IS 1554 Part 2. | | Agree |
| Product Specification for Netco Make 3.3KV PVC DWA Copper Power Cable 95sqmm | | |
| Specification विनिर्देश | Sub-Spec उप-विनिर्देश | Value मूल्य |
| GENERIC | PVC Insulated (Heavy Duty) Electric cables for working voltages from 3.3 kV up to and including 11 kV conforming to | IS:1554-Part 2: 1988 latest |
| | ISI Marked | Yes |
| | BIS Marekd if "Yes" BIS License Number (CM/L Number) - Must declare | CM/L 8051865 |
| | Cable Category | 01 |
| | Types of cable | "Three-core armoured, unscreened" |
| | Voltage Grade | 3.3/3.3 kV |
| | Conductor material (as per Cl.3 of IS:1554 (Part 2):1988 latest) | Copper |
| | Insulation Type (as per Cl.4.1 of IS:1554 (Part 2):1988 latest) | Type A |
| | Outer sheath type | Type ST1 |
| | Nominal Area of Conductor (in Sq.mm)" | 95 |
| CONSTRUCTIONAL | Armouring | Galvanized Double steel round wire |
| | Cable packing type (Wound on drum) (as per Cl. 21 of IS:1554 (Part 2): 1988 latest | Yes |
| | Identification on cable as per Cl. 20 of IS:1554 (Part 2): 1988 latest | Yes. Marked |
| | Marking on cable (as per Cl. 21 of IS:1554 (Part 2): 1988 latest | Yes. Marked |
| CERTIFICATIONS | Availability of Type test report with additional requirements for use in Mines from Central Government/NABL/ILAC accredited laboratory to prove conformity to the specification | Yes |
| | Test report number - Must declare | ATCC2015091208 |
| | Report date - Must declare | 12-09-2015 |
| | Name of lab - Must declare | Amit Test |
| | Address of lab - Must declare | 19/168 Saral Rohilla |
| | All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand | Yes |
| Buyer Defined Additional Specification for खरीदार परिभाषित अतिरिक्त विशिष्टता के लिए Netco Make 3.3KV PVC DWA Copper Power Cable 95sqmm | | |
| Specification विनिर्देश | | Value मूल्य |
| 1. PVC Insulated (Heavy Duty) Electric cables for working voltages from 3.3 kV up to and including 11 kV conforming to : IS:1554-Part 2: 1988 latest 2. ISI Marked : Yes, 3. Conductor material (as per Cl.3 of IS:1554 (Part 2):1988 latest) : Copper | | Agree |
| 4. Outer sheath type : Type ST1 5. Identification on cable as per Cl. 20 of IS:1554 (Part 2): 1988 latest : Yes. Marked 6. Marking on cable (as per Cl. 21 of IS:1554 (Part 2): 1988 latest : Yes. | | Agree |
| 7. Cable packing type (Wound on drum) (as per Cl. 21 of IS:1554 (Part 2): 1988 latest : Yes 8. All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand: Yes | | Agree |
| 9. Availability of Type test report with additional requirements for use in Mines from Central Government/NABL/ILAC accredited laboratory to prove conformity to the specification: Yes 10. Reel length / cable length in a drum: 250 Mtrs +/- 5% | | Agree |
| 11. Self certificate from the manufacturer to the following extent that 3.3 KV grade cables for use in mine are as per DGMS circular no. DGMS/Tech. Circular (Electrical), (Approval) No. 12 Dhanbad, dated 25.05.2015 and IS 1554 Part 2. | | Agree |
| ePBG Detail ईपीबीजी विवरण | | |
| Advisory Bank सलाहकार बैंक : | State Bank of India | |
| ePBG Percentage(%) ईपीबीजी प्रतिशत (%) : | 10.00 | |
| The bidder shall furnish ePBG as applicable as per bid's terms and conditions बोली लगाने वाले को बोली के नियमों और शर्तों के अनुसार लागू ईपीबीजी प्रस्तुत करना होगा | | |

Terms and Conditions | नियम और शर्तें

1. General Terms and Conditions-

- 1.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.
- 1.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

2. Buyer Added Bid Specific Terms and Conditions-

2.1 Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

2.2 Generic

Without prejudice to Buyer's right to price adjustment by way of discount or any other right or remedy available to Buyer, Buyer may terminate the Contract or any part thereof by a written notice to the Seller, if:

- i) The Seller fails to comply with any material term of the Contract.
- ii) The Seller informs Buyer of its inability to deliver the Material(s) or any part thereof within the stipulated Delivery Period or such inability otherwise becomes apparent.
- iii) The Seller fails to deliver the Material(s) or any part thereof within the stipulated Delivery Period and/or to replace/rectify any rejected or defective Material(s) promptly.
- iv) The Seller becomes bankrupt or goes into liquidation.
- v) The Seller makes a general assignment for the benefit of creditors.
- vi) A receiver is appointed for any substantial property owned by the Seller.
- vii) The Seller has misrepresented to Buyer, acting on which misrepresentation Buyer has placed the Purchase Order on the Seller.

2.3 Scope of Supply:

Scope of supply (Bid price to include all cost components) : Only supply of Goods

2.4 Buyer Added Bid Specific ATC:

Buyer Added text based ATC clauses

1. Product / Product delivery should comply with, ensuring the quality of service, protection of the environment and health & safety during and after their activities, as per Company / Govt. norms.
2. The seller has to upload all relevant documents (like Guarantee/Warranty certificate, Delivery Challan, E-waybill, Test report, any other document mentioned in the contract which ever is applicable) in the GeM portal while generating Invoice.
3. The clarification/shortfall documents if any will be sought only once. The clarification document submitted in the representation after technical acceptance will not be accepted.
4. Mahanadi Coalfields Limited (MCL) has on boarded the TReDS platform through Receivables Exchange of Inida Limited (RXIL). TReDS is an online discounting platform primarily meant for MSME vendor to get their trade receivables financed through auction mechanism where multiple financiers can participate in a very transparent manner. MSME vendors of MCL are requested to register themselves on RXIL TReDS platform to avail the above benefits. For more details, visit: <https://www.rxil.in/>.
5. The clarification/representation submitted against the BID document through any mode other than GeM portal will not be considered.
6. The bidder is only eligible for participation in a BID on compliance of the Restriction under Rule 144(xi) (as amended vide OM No. F.7/10/2021-PPD dated 23.02.2023). The certificate of this effect need to be submitted by the bidder.
7. Warranty: Warranty shall remain valid for eighteen (18) months from the date of receipt and acceptance of material at consignee's end or twelve (12) months from the date of its use/fitment/commissioning, whichever is earlier. All cases of warranty replacement of failed item will be decided on the basis of joint inspection of the failed item held between the user and the manufacturer's representative. The supplier will have to depute representative for joint inspection within 10 days of intimation of warranty failure. In case if he fails to come for joint inspection within 10 days of intimation, the warranty claim raised by the consignee shall be treated as final and supplier will be liable to make warranty replacement of the failed item.
8. At the time of supply, following details to be furnished by the bidders: (1). Service Voltage (2). Make of the cable (3). Type of the cable (4). No of cores (5). Sectional area of core (6). Standard to which the cable conform. (7). Type of conductor (8). Flexibility class (9). Type of insulation (10). Thickness of insulation (11). Diameter under armour and over armour (12). Thickness of inner sheath and outer sheath (13). Type of Armouring (14). Conductivity of armour (15) Maximum resistance of the conductor at 20 deg. Celsius (16). Minimum No of wires in the conductor. (17). Minimum bending radius of the finished cable (21). Continuous current carrying capacity of the cable: (a). In ground (ground temperature 30 deg. Celsius) (b). In air (Ambient air temperature : 40 deg. Celsius) (18). Maximum conductor temperature during continuous operation (19). Short circuit rating of the cable: (a). one second rating (b). Three second rating (20). Maximum conductor temperature during short circuit
9. Supplier should furnish all the test reports and certificates to consignee at the time of supply of cables
10. Documents to be submitted by all bidders during bid submission:-
 - I. (a) Bid specific authorization having bid no. from manufacturer of cables
 - (b) BIS license for ISI marking as per IS 1554 Part II on offered cables
 - (c) Documents related to Micro-Small enterprise status of firm.

2.5 Certificates:

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

2.6 Generic

Buyer Organization specific Integrity Pact shall have to be complied by all bidders. Bidders shall have to upload scanned copy of signed integrity pact as per Buyer organizations policy along with bid. [Click here to view the file](#)

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।