

01
02-03-15

04

District Ganjam Block Buguda Village Arakhapur
 School Name Arakhapur V.P.S. School Code 21190500902
 No. of Student Girls 149 Boys 146
 Status of toilet Existing 01 (Girls) Note Existing
 Toilet Requirement Girls 0 Boys 01

If Existing:

Sl.No	Item	Condition	
		Good in Nos.	To be replaced in Nos.
1	WC	<u>1 nos -</u>	
2	Urinals	<u>-</u>	
3	Doors (size)	<u>2 x 0.75 x 1.95</u>	
4	Floor level	<u>0.800</u>	
5	Wall level	<u>2.100</u>	
6	Internal plaster	<u>Good</u>	
7	Outer plaster	<u>Good</u>	
8	Inspection Chamber	<u>-</u>	
9	Lease pit / septic tank	<u>1 nos -</u>	

Source of Water Bore well with pump Hand pump
 Water tank Ground Overhead
 Water tank Capacity

Remarks if any: One toilet for boys is required. Girls toilet has no urinals & open to sky. RCC roof for girls urinals is required.

Sign of School Headmaster

Sign of School Mgt Committee

Sign of Surveyor

Headmaster
Govt. Upper Primary School
ARAKHAPUR (Ganjam)
 Name

Name

9438277319
 Name S.K. Padhi

Srimanohar Jena
9668637874

Handwritten signature

Handwritten signature
3/3/15