

DT: 24.01.2015 (6)

"स्वच्छ भारत अभियान"

DISTRICT: NAYAGARH BLOCK: Bhapur

VILLAGE: Tarabalo

SCHOOL NAME: Tarabalo Govt. MES

SCHOOL CODE: 010790T

NO. OF STUDENT: 229 GIRLS: 112

BOYS: 107

STATUS OF TOILET: EXISTING: YES

NOT EXISTING:

TOILET REQUIREMENT: GIRLS: NO

BOYS: Yes.

IF EXISTING:

SI.NO.	ITEM	CONDITION	
		GOOD IN NOS.	TO BE REPLACED IN NOS.
1	WC	1 Girls	1 for Boys new
2	URINALS	1 Girls	1 for Boy new
3	DOORS(SIZE)	3 Girls	2 for Boys new
4	FLOOR LEVEL	✓	Repair required Boys
5	WALL LEVEL	✓	B. do
6	INTERNAL PLASTER	✓	do
7	OUTER PLASTER	✓	do
8	INSPECTION CHAMBER	X	new construction
9	LEASE PIT/ SEPTIC TANK	X	new construction required.

SOURCE OF WATER:

BORE WELL WITH PUMP:

HAND PUMP: YES

WATER TANK:

GROUND:

OVERHEAD: YES

WATER TANK CAPACITY: 450lt

Remarks if any:

1. Over head tank is damaged & no water supply connection is exist.
2. Boys existing structure of urinal & toilet is in very bad condition.
3. Water for toilet use is carried through bucket.

Sign of School Head Master

Sign of School Mgt Committee

Sign of Surveyor

Headmaster
Tarabalo Govt. M.E. (U.P.) School
NAME: Tarabalo

NAME:

Chair Person S.M.C.
Tarabalo Govt. U.P.S.

NAME:

S.S. Pattanayak

Bejayalaxoni Parida.

for

Baakeontha Kheortia. Vann

Vann