

08  
27-01-15

(25)

District Dhankanal Block Gondi 9 Village Bavady  
 School Name Aswakhola Anchaling H.S School Code 211 40317201  
 No. of Student Girls- 61 Boys- 71  
 Status of toilet Existing 1 cluster Not Existing  
 Toilet Requirement Girls - 01 Boys -

If Existing:

Sl.No	Item	Condition	
		Good in Nos.	To be replaced in Nos.
1	WC	<u>01</u>	
2	Urinals	<u>NIL</u>	
3	Doors (size)	<u>Toilet - 0.65 x 1.53</u> <u>URINAL - 0.53 x 1.37</u>	
4	Floor level	<u>+ 0.60</u>	
5	Wall level	<u>TOILET - 1.87</u> <u>URINAL 1.30</u>	
6	Internal plaster	<u>Good</u>	
7	Outer plaster	<u>Good</u>	
8	Inspection Chamber	<u>NIL</u>	
9	Lease pit / septic tank	<u>Leach pit - 1</u>	

Source of Water  Bore well with pump /  Hand pump  
under execution.  
 Water tank  Ground /  Overhead  
 Water tank Capacity N.A. bucket using.

Remarks if any: No urinal for boys: Boys urinate on floor. Urinal open to sky and without urinating pan. Hence both Girls and boys toilets may be constructed considering the strength of students.

Ganesh Kumar Sahoo  
Sign of School head master

Sign of School Mgt Committee

[Signature]  
27-01-2015  
Sign of Surveyor

Mobile-NO- 9178727404

9 43 887 9727

Name

Name

Name

S.K. Lejha

[Signature]  
27/1/15