

04

28-1-15

District Dhamcanal Block Gandia

Village Bishanpur Karagola

(26)

School Name Bishanpur Karagola PS

School Code 21140317401

No. of Student Girls- 30

Boys- 39

Status of toilet Existing 1 cluster

Not Existing

Toilet Requirement Girls

Boys - 01

If Existing:

Sl.No	Item	Condition	
		Good in Nos.	To be replaced in Nos.
1	WC		01
2	Urinals	NIL	
3	Doors (size)		Urinal 1.38 x 0.77 x 4 Toilet 1.53 x 0.57
4	Floor level	+ 0.20	
5	Wall level	(2.14 + 1.74) / 2	
6	Internal plaster	N	Not good
7	Outer plaster		Not good
8	inspection Chamber		
9	Lease pit / septic tank		defunct

Source of Water

Bore well with pump /

Hand pump ✓

(Defunct)

Open well ✓

Water tank

Ground ✓

/

Overhead

Water tank Capacity

$\frac{1}{4} (0.84)^2 \times 0.63$

Remarks if any: Reported that construction of girls toilet under process and Rs 60000 has been sanctioned out of 1.20,000.00. One boys toilet may be constructed considering the need.

Rabindra Khateja

Sign of School head master

**Bishanpur Karagola Primary School  
Gandia Circle, Dhamcanal**

Name

7894184533

Sign of School Mgt Committee

Name

Sign of Surveyor

Name

Sud  
28-01-15  
Sonyia Ranjan Singh  
Subash Ku. Poudhi

Handwritten signature  
28/1/15