

Dt. 22-01-2015

33

District Dhenkanal Block Gondia Village Ramein Khamar
 School Name Ramein VPS School Code 21140319101
 No. of Student Girls- 27 Boys- 41
 Status of toilet Existing 01 Not Existing
 Toilet Requirement Girls - Boys - 01

If Existing:

Sl.No	Item	Condition	
		Good in Nos.	To be replaced in Nos.
1	WC	<u>01</u>	
2	Urinals	Toilet <u>Urinal - 1.48</u> Toilet <u>2.10</u>	<u>NIL</u>
3	Doors (size)	<u>0.60 x 1.83 (Urinal)</u> <u>0.75 x 1.38 (Toilet)</u>	
4	Floor level	<u>+ 200</u>	
5	Wall level	Toilet <u>2.10</u> <u>1.48</u> <u>Urinal</u> <u>2.10</u>	<u>Toilet open to sky</u>
6	Internal plaster		<u>fx</u>
7	Outer plaster		<u>fx</u>
8	Inspection Chamber	<u>NIL</u>	
9	Lease pit / septic tank		<u>Open lead pit</u>

Source of Water Bore well with pump / Hand pump - 01 (defunct)
 Water tank Ground / Overhead On adequate water with hand water
 Water tank Capacity 1.12 x 0.94 x 0.65

Remarks if any: Toilet is open to sky. Pan used without trap. Girls toilet and 8 construction. One Boys toilet rapid and may be constructed. Water course to be renovated

Rohit Dehura
 Sign of School head master
22-01-15

Rohit Dehura
 Sign of School Mgt Committee
22-01-2015

Sudhane
22-01-2015
 Sign of Surveyor

9178663542
 Name Headmaster
Ramein U.P. School
Dhenkanal

Name _____ Name _____

Handwritten signature

Manoranjan School