

22-01-2018

(20)

District Dhenkanal Block Grondia Village - Sandapasi  
 School Name Sandapasi Primary School School Code 21140315503  
 No. of Student Girls- 16 Boys- 22  
 Status of toilet Existing 1 clefts Not Existing  
 Toilet Requirement Girls Boys - 01

If Existing:

Sl.No	Item	Condition	
		Good in Nos.	To be replaced in Nos.
1	WC	<u>01</u>	
2	Urinals	<u>NIL</u>	
3	Doors (size)	<u>Toilet - 0.57 x 1.68</u> <u>Urinal 0.73 x 1.37</u>	
4	Floor level	<u>Toilet &amp; Urinal</u>	
5	Wall level	<u>Toilet 2.003</u> <u>Urinal 1.49</u>	
6	Internal plaster	<u>-</u>	<u>Not good</u>
7	Outer plaster	<u>✓</u>	<u>Not good/No plaster</u>
8	Inspection Chamber	<u>NIL</u>	
9	Lease pit / septic tank	<u>= 01 (Leach pit)</u>	

Source of Water Bore well with pump /  Hand pump with more iron content and iron scaling.  
 Water tank  Ground /  Overhead  
 Water tank Capacity 01 - (damaged and can be repaired)  
4 x 0.85 x 0.85 x 0.60

Remarks if any: Walls are cracked may be due to differential settlement  
Soil - Black cotton. As the construction being done on floor  
hence one boys toilet may be constructed

Satyananda Bhoi  
 Sign of School head master  
 Headmaster  
 Sandapasi P.P. School

Sign of School Mgt Committee

[Signature]  
 22-01-18  
 Sign of Surveyor

Name  
 phon. 9439674432

Name

Name

[Signature]  
 22/1/18

Manoranjan Sahoo