

**SURVEY REPORT OF SCHOOLS TOILET UNDER "SWACHHA VIDYALAYA ABHIYAN" CONDUCTING
BY KANIHA AREA, TALCHER COALFIELDS, MCL**

District: - Rayagada

Block: - GUNUPUR

Village: - PRADHANIGUDA.

School Name: - PRADHANIGUDA P.S.

School Code: - 212709037 01

No. of Student: - 19

Girls: - 07

Boys: - 12

Status of toilet: -

Existing: - ✓

Not existing: -

Toilet Requirement: -

Girls: -

Boys: -

If Existing: -

Sl no.	Item	Condition	
		Good in Nos.	To be replaced in Nos.
1	WC	01 (O.K)	
2	Urinals	only tile floor	
3	Doors(Size)	03 x 0.60 x 1.35 (steel) O.K	
4	Floor level	W.C - O.K Urinal - 2 x 1.40 x 1.08	→ damaged.
5	Wall level	Urinal -	damaged - 1 x (1.40 x 1.08) x 1.50 (2") floor - 3 x 0.25 x 0.25 x 1.50
6	Internal Plaster	O.K (Exclud ^d damage)	
7	Outer plaster	O.K (Exclud ^d damage)	
8	Inspection Chamber	01 x 0 (O.K)	
9	Lease Pit/Septic tank	01 x 0 (O.K)	

Source of Water

Bore well with pump NO /

Hand pump 01

Water tank

Ground NO /

Overhead NO.

Water tank Capacity

Remarks if any: The Existing toilet needs repair. i.e R.C.C. roof change.

Sign of School Head Master

Anirudha Mishra
Primary School, Pradhaniguda
DIST RAYAGADA

Name ANIRUDHA MISHRA

Email ID

Ph.No. 9437775545

Sign of School Mgt Committee

K. Saranga
S.M.C; PRADHANIGUDA P.S
GUNUPUR, Dist Rayagada

Name KOMPALLO SARANGA

Email ID

Ph.No. 01778202049

Sign of Surveyor

Name MANJULU JANA NAYAK

Email ID

Ph.No. 9158773299