

17

DF-20-1-15

District Tharsuguda Block Tharsuguda Village Talma
 School Name Mundachipa Project PS School Code 21020101802
 No. of Student 25 Girls- 15 Boys- 10
 Status of toilet Existing 1 Block Not Existing
 Toilet Requirement Girls Boys 1

If Existing:

Sl.No	Item	Condition	
		Good in Nos.	To be replaced in Nos.
1	WC	1 Nos.	
2	Urinals	2 Nos	
3	Doors (size)	1 x 2' x 5' 10"	
4	Floor level	1RS	
5	Wall level	4 1/3" B/W	
6	Internal plaster	✓	
7	Outer plaster	✓	
8	Inspection Chamber	✓	
9	Lease pit/ septic tank	X	

Source of Water Bore well with pump / Hand pump ✓
 Water tank Nil Ground / Overhead
 Water tank Capacity NA

Remarks if any: Students carry water by bucket to Toilet. Present block consisting of one WC and two urinals is insufficient. 1 Block for boys is required.

Sign of School head master
 Name Ashok Kumar Mahapatra
DF-20-1-15

Sign of School Mgt Committee
 Name

Sign of Surveyor
 Name B. T. Ramteke
P. K. Nayak

DF-20-1-15