

(01) (28)

District Dhenkanal Block Odapada Village Sadasiwpure  
 School Name Sadasiwpur Primary School School Code 21140714102  
 No. of Student Girls- 22 (Twenty two) Boys- 15  
 Status of toilet Existing Not Existing  
 Toilet Requirement Girls Boys - 01

If Existing:

Sl.No	Item	Condition	
		Good in Nos.	To be replaced in Nos.
1	WC		Could not be inspected as locked and key unavailable. Reported damaged
2	Urinals	NIL	
3	Doors (size)	1.63 x 0.77 2 x 1.28 x 0.77	
4	Floor level	+ 0.30	
5	Wall level	+ 1.68	
6	Internal plaster	Good	
7	Outer plaster	Good	
8	Inspection Chamber	NIL	
9	Lease pit / septic tank	or -	01 defunct

Source of Water Bore well with pump / Hand pump open well  
 Water tank Ground / Overhead using bucket  
 Water tank Capacity NA

Remarks if any: No urinals available. One WC available which is defunct. Recommended for constn. of both boys & girls toilet

Jyotismayee Mishra (Asst to)  
 Sign of School head master Sign of School Mgt Committee  
 Ph - 9937651114  
H.M. Bipin bihari Satpathy  
 Name 9937389195 Name

S.K. Reddy  
 Sign of Surveyor 16-01-15  
S.K. Reddy  
 Name 9438879727  
MT-C D

MT-C D  
16/01/15