

146



"स्वच्छ भारत अभियान"

water facility not optimum for large strength of the school

(39) (7)

DISTRICT: Ganjam BLOCK: Swiada

VILLAGE: Lokamari

SCHOOL NAME: LOKAMARI UPS

SCHOOL CODE: 2119 220760

NO. OF STUDENT: 392 GIRLS: 204

BOYS: 188

STATUS OF TOILET: EXISTING: ✓

NOT EXISTING:

TOILET REQUIREMENT: GIRLS: 1 WC

BOYS: (1+1)

IF EXISTING: (1 WC + urinal) newly constructed for girls

SI.NO.	ITEM	CONDITION	
		GOOD IN NOS.	TO BE REPLACED IN NOS.
1	WC	1	1+1
2	URINALS	1	1+1
3	DOORS(SIZE)	/	✓
4	FLOOR LEVEL		✓
5	WALL LEVEL		✓
6	INTERNAL PLASTER		✓
7	OUTER PLASTER		✓
8	INSPECTION CHAMBER		
9	LEASE PIT/ SEPTIC TANK		✓

SOURCE OF WATER:

BORE WELL WITH PUMP: X

HAND PUMP: (01)

WATER TANK:

GROUND: X

OVERHEAD: (01)

WATER TANK CAPACITY: 750 lit

phd supply water

Remarks if any:

- electricity available

- source of water (1 handpump + only 1 hour daily phd supply)

*Santosh Kumar*  
3-3-15  
Sign of School Head Master

*Pratap Kumar Maharana*  
3-3-2015  
Sign of School Mgt Committee

*Swagat Das*  
3/3/15  
Sign of Surveyor  
MT (EW)

NAME: SANTOSH KUMAR  
GOUDA  
9861029342

NAME: PRATAP K.V.  
MAHARANA  
(member, SMC)

NAME: SWAGAT  
DAS

HEADMASTER  
Nehru Govt. U.P. School  
Lokamari, (Gm.)